



TOP

NOTES:

1. MARKER SHALL HAVE A 2" DIA, BRASS INSERT CAST IN TOP. PLACE MARKER 1'-0" INSIDE R/W WITH A DIRECTION ARROW & DISTANCE FROM MARKER TO VALVE STAMPED ON BRASS INSERT.
2. MARKER SHALL BE PAINTED WATER BLUE.
3. THE LETTERS "WV" SHALL BE ON THE ROAD SIDE OF THE MARKER.
4. LOCATE AT ALL BURIED VALVES ON MAINS GREATER THAN 12".

SIDE

CPW VALVE MARKER

CHARLESTON WATER SYSTEM		
CPW VALVE MARKER		
APPROVED BY: CWS	DATE: MAR 2000	DRAWING NO. 29
SCALE: NTS	REVISED: FEB 2010	