



NOTES:

1. LOCATE TRANSDUCER PER MANUFACTURER'S RECOMMENDATIONS TO AVOID INTERFERENCE FROM PUMPS, WALL, ETC. IN THE WETWELL.
2. IF ULTRASONIC NEEDS TO EXTEND OUT INTO WETWELL, CONTACT PUMP STATION MAINTENANCE MANAGER FOR DIFFERENT MOUNTING DETAIL.

TRANSDUCER MOUNTING PLATE DETAIL

CHARLESTON WATER SYSTEM		
TRANSDUCER MOUNTING PLATE DETAIL		
APPROVED BY: CWS	DATE: MARCH 1999	DRAWING NO. 65
SCALE: NTS	REVISED: FEB 2010	